## **COMPRESSOR DATA SHEET**

**Rotary Compressor: Fixed Speed** 

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Atlas Copco					
	Model Number: GA 250-200 (W)	Date:	09-01-2014			
2	Air-cooled X Water-cooled	Type:	Screw			
	X Oil-injected Oil-free	# of Stages:	1			
	Rated Capacity at Full Load Operating					
3*	Pressure a, e	1113	acfm <sup>a,e</sup>			
4	Full Load Operating Pressure b	200	psig b			
5	Maximum Full Flow Operating Pressure c	203	psig <sup>c</sup>			
6	Drive MotorNominal Rating	300	hp			
7	Drive Motor Nominal Efficiency	96.2	percent			
8	Fan Motor Nominal Rating (if applicable)	-	hp			
9	Fan Motor Nominal Efficiency	-	percent			
10*	Total Package Input Power at Zero Flow	68	kW <sup>e</sup>			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	267	$k\textbf{W}^{\text{d}}$			
12*	Specific Package Input Power at Rated		kW/100 cfm <sup>e</sup>			
	Capacity and Full Load Operating Pressure	24.0				

For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program:

NOTES:

Member

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.

  d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 030

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.