## COMPRESSOR DATA SHEET

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: Atlas Copco		
	Model Number: GA 160 VSD-125 (W)	Date:	04-01-2015
2	Air-cooled X Water-cooled	Type:	Screw
	X Oil-injected Oil-free	# of Stages:	1
3	Rated Operating Pressure	100	psig <sup>b</sup>
4	Drive Motor Nominal Rating	215	hp
5	Drive Motor Nominal Efficiency	94.9	percent
6	Fan Motor Nominal Rating (if applicable)	0.9	hp
7	Fan Motor Nominal Efficiency	30.0	percent
8*	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	<b>204.7</b> Max	1167.0	17.54
	177.8	1041.0	17.08
	163.2	967.0	16.88
	135.7	817.0	16.61
	109.9	664.0	16.55
	<b>49.3</b> Min	270.0	18.26
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	0.0	kW
10	35.00		
	30.00		
	Specific Power (KW/100 ACFM) 20.00 20.00		
	Specific (KW/100) 20.00		
	15.00		
	10.00    50   100   150   200   250   300   350   400   450   500   550   600   650   700   750   800   850   900   950   1000   1050   1100		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>

NOTES:


Member

a. Measured at the discharge terminal point of the compressor package in accordance with

ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ROT 031

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.