

COMPRESSOR DATA SHEET
Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: Atlas Copco		
2	Model Number: GA37VSD+ 175 AP	Date:	8/1/2016
	<input checked="" type="checkbox"/> Air-cooled <input type="checkbox"/> Water-cooled	Type:	Screw
	<input checked="" type="checkbox"/> Oil-injected <input type="checkbox"/> Oil-free	# of Stages:	1
3	Rated Operating Pressure	125	psig ^b
4	Drive Motor Nominal Rating	50	hp
5	Drive Motor Nominal Efficiency	96	percent
6	Fan Motor Nominal Rating (if applicable)	1.3	hp
7	Fan Motor Nominal Efficiency	73	percent
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	47.2 Max	255.7	18.4
	44.8	243.6	18.4
	33.0	176.3	18.7
	26.6	139.1	19.1
	20.4	101.7	20.0
	17.6 Min	84.2	20.8
9*	Total Package Input Power at Zero Flow ^{c, d}		1.1 kW
10	<p align="center">Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity</p>		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

- NOTES:
- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
 - The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
 - No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 - Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member:



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\frac{m^3}{min}$	$\frac{ft^3}{min}$	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	15 to 50	+/- 6	+/- 7	
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	