

## **COMPRESSOR DATA SHEET**

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Atlas Copco						
2	Model Number: GA 37 VSD - 175 AP	Date:	8/1/2018				
	X Air-cooled Water-cooled	Туре:	Screw				
	X Oil-injected Oil-free	# of Stages:	1				
3	Rated Operating Pressure	125	psig <sup>b</sup>				
4	Drive Motor Nominal Rating	50	hp				
5	Drive Motor Nominal Efficiency	93	percent				
6	Fan Motor Nominal Rating (if applicable)	5.1	hp				
7	Fan Motor Nominal Efficiency	77	percent				
8*	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	46.8 Max	238.3	19.7				
	44.7	226.6	19.7				
	37.1	187.4	19.8				
	31.8	161.7	19.7				
	23.4	112.1	20.9				
	15.2 Min	64.9	23.4				
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	0.0	kW				
10	35.0  30.0  30.0  25.0  10.0  10.0  Capacity  Note: Graph is only a visual repr Note: Y-Axis Scale, 0 to 25%  X-Axis Scale, 0 to 25%	(ACFM) esentation of the data in Section 8 00acfm increments if necessary above	300.0				

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

Member:

- a. Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

  b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.

  c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zer Flow Power
m <sup>3</sup> / min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.