

COMPRESSOR DATA SHEET
Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR

1	Manufacturer: Atlas Copco			
2	Model Number: GA 45 VSD - 175 AP	Date:	8/1/2018	
	<input checked="" type="checkbox"/> Air-cooled <input type="checkbox"/> Water-cooled	Type:	Screw	
	<input checked="" type="checkbox"/> Oil-injected <input type="checkbox"/> Oil-free	# of Stages:	1	
3	Rated Operating Pressure	125	psig ^b	
4	Drive Motor Nominal Rating	60	hp	
5	Drive Motor Nominal Efficiency	93	percent	
6	Fan Motor Nominal Rating (if applicable)	5.1	hp	
7	Fan Motor Nominal Efficiency	83	percent	
8*	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	57.5	Max	283.7	20.3
	55.1		271.5	20.3
	46.6		230.4	20.2
	39.4		193.3	20.4
	26.5		122.0	21.7
9*	16.6	Min	64.7	25.7
	Total Package Input Power at Zero Flow ^{c, d}		0.0	kW
10	<p align="center">Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity</p>			

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member:



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m^3/min	ft^3/min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	15 to 50	+/- 6	+/- 7	
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

5/11 R6

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.