COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR CO.			
1	Manufacturer: Atlas Copco			
2	Model Number: ZR 75VSD-150	Date:	12-14-2018	
	Air-cooled x Water-cooled	Type:	Screw	
	Oil-injected x Oil-free	# of Stages:	2	
3	Rated Operating Pressure	130	psig ^b	
4	Drive Motor Nominal Rating	101	hp	
5	Drive Motor Nominal Efficiency	93.4	percent	
6	Fan Motor Nominal Rating (if applicable)	-	hp	
7	Fan Motor Nominal Efficiency	Fan Motor Nominal Efficiency -		
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	93.3 Ma	416	22.4	
Out	79.8	351	22.7	
8*	67.2	286	23.5	
	55.4	222	25.0	
	44.1 Mi	n 157	28.1	
9*	Total Package Input Power at Zero Flow ^{c, d}	12.7	kW	
10	35.0 35.0 30.0			
	30.0 Specific Power 25.0 25.0 20.0 20.0 20.0 20.0 20.0 20.0			
	0 50 100 150 200 Capacity (Note: Graph is only a visual repree Note: Y-Axis Scale, 10 to 35, + 5kW/10t X-Axis Scale, 0 to 25% o	sentation of the data in Section 8 acfm increments if necessary above	450 500 35	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES: a. Measure

a. Measured at the discharge terminal point of the compressor package in accordance with

Member

- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.