## COMPRESSOR DATA SHEET

**Rotary Compressor: Variable Frequency Drive** 

	MODEL DATA - FOR CO		
1	Manufacturer: Atlas Copco		
	Model Number: ZR 132VSD+ -150	Date:	12-14-2018
2	Air-cooled x Water-cooled	Type:	Screw
	Oil-injected x Oil-free	# of Stages:	2
3	Rated Operating Pressure	125	psig <sup>b</sup>
4	Drive Motor Nominal Rating	2 x 87	hp
5	Drive Motor Nominal Efficiency	97.0	percent
6	Fan Motor Nominal Rating (if applicable)	-	hp
7	Fan Motor Nominal Efficiency	-	percent
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	<b>144.1</b> Ma	x 760	19.0
0*	115.7	618	18.7
8*	90.0	476	18.9
	66.4	333	19.9
	<b>43.8</b> Mi	n <b>191</b>	22.9
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>		kW
10	40.0  35.0  30.0  30.0  20.0  15.0  10.0  140  190  240  290  340  390  440  Capacity  Note: Graph is only a visual repre  Note: Y-Axis Scale, 10 to 35, + 5kW/10	sentation of the data in Section 8	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



	ume Flow Rate cified conditions	Volume Flow Rate	Specific Energy ne Flow Rate Consumption	
m <sup>3</sup> /min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.