COMPRESSOR DATA SHEET

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR CO.		
1	Manufacturer: Atlas Copco		
2	Model Number: ZR 160VSD+ -150	Date:	12-14-2018
	Air-cooled x Water-cooled	Туре:	Screw
	Oil-injected x Oil-free	# of Stages:	2
3	Rated Operating Pressure		
4	Drive Motor Nominal Rating	2 x 107	hp
5	Drive Motor Nominal Efficiency	97.0	percent
6	Fan Motor Nominal Rating (if applicable)	-	hp
7	Fan Motor Nominal Efficiency -		percent
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	175.5 Ma	x 842	20.8
04	139.3	679	20.5
8*	107.0	516	20.7
	77.3	353	21.9
	49.2 Mi	189	26.0
9*	Total Package Input Power at Zero Flow ^{c, d}		kW
10	35.0 30.0 30.0 25.0 20.0 15.0 10.0 140 190 240 290 340 390 440 4 Capacity (Note: Graph is only a visual repre Note: Y-Axis Scale, 10 to 35, +5kW/100 X-Axis Scale, 0 to 25% o	ACFM) entation of the data in Section 8 acfm increments if necessary above 2	40 790 840 890

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with

ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
 c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ /min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.