## COMPRESSOR DATA SHEET

**Rotary Compressor: Variable Frequency Drive** 

	MODEL DATA - FOR C				
1	Manufacturer: Atlas Copco				
2	Model Number: ZR 160VSD+ -150		Date:	12-14-2018	
	Air-cooled x Water-cooled	Type:	Screw		
	Oil-injected x Oil-free		# of Stages:	2	
3	Rated Operating Pressure		100	psig <sup>b</sup>	
4	Drive Motor Nominal Rating		2 x 107	hp	
5	Drive Motor Nominal Efficiency		97.0	percent	
6	Fan Motor Nominal Rating (if applicable)		-	hp	
7	Fan Motor Nominal Efficiency		-	percent	
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>	
	175.2 N	Лах	958	18.3	
Ovk	133.1		766	17.4	
8*	97.9		575	17.0	
	67.1		383	17.5	
	38.9	Min	192	20.3	
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>			kW	
10	35.0  30.0  30.0  25.0  20.0  15.0  10.0  140 190 240 290 340 390 440 490  Capacie  Note: Graph is only a visual re  Note: Y-Axis Scale, 10 to 35, +5kW	ty (AC	tation of the data in Section 8	890 940 990 1040	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with

Mombor

- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
   c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m <sup>3</sup> /min	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	]
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10%
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031

10/11 R7 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.