| | | | Rotary | COMPRESSOR DA1 | | | |
|--|-----------------------------|--|--|---|---|--|------------------------------|
| | | | | DEL DATA - FOR CON | | |] |
| | 1 Manufacturer: Atlas Copco | | | | | | |
| | | Model Nu | mber: | ZT 75 VSD-125 | Date: | 12-17-2018 | |
| | 2 | x Air-cooled | | Water-cooled | Type: | Screw | |
| | | Oil-injected | | x Oil-free | # of Stages: | 2 | |
| | 3 | Rated Ope | erating Pres | sure | 125 | psig ^b | |
| | 4 | Drive Mot | tor Nominal | Rating | 101 | hp | |
| | 5 | Drive Mot | or Nominal | Efficiency | 93.4 | percent | _ |
| | 6 | Fan Motor Nominal Rating (if applicable) | | | 5.4 | hp | |
| | 7 | Fan Motor | Nominal E | Efficiency | 81.3 | percent | |
| | 8* | Input Power (kW) | | | Capacity (acfm) ^{a,d} | Specific Power (kW/100 acfm) ^d | _ |
| | | 100.2 Max | | | 420 | 23.9 | |
| | | 85.9 | | | 354 | 24.3 | _ |
| | 0. | | | 73.1 | 289 | 25.3 | _ |
| | | | | 61.1 | 223 | 27.4 | _ |
| | | 49.5 Min | | | 157 | 31.5 | - |
| | 9* | T . 1 D . 1 | | | 15.5 | 1 11/ | - |
| | 9* | Total Package Input Power at Zero Flow ^{c, d} | | | 15.5 | kW | - |
| | 10 | Specific Power (kW100 A.CFM) | 40.0 35.0 30.0 25.0 20.0 | | | | |
| | | | 15.0 | 50 100 150 200 2 Capacity (A Note: Graph is only a visual repress Note: Y-Axis Scale, 10 to 35, + 5kW/100 X-Axis Scale, 0 to 25% ov | entation of the data in Section 8 acfm increments if necessary above | 450 500 35 | |
| *For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org NOTES: a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document. | | | | | | | |
| Compresse | d Air & Gas Institute | | at s | olume Flow Rate pecified conditions | Volume Flow Rate | Specific Energy Consumption | No Load / Zero Flow Power |
| | | | $\frac{\text{m}^3 / \text{min}}{\text{Below 0.5}}$ | <u>ft3 / min</u> | % | % | - |
| | | | 0.5 to 1.5 | Below 15 15 to 50 | +/- 7 +/- 6 | +/- 8 +/- 7 | +/- 10% |
| | | | 1.5 to 15 | 50 to 500 | +/- 5 | +/- 6 | |
| ROT 031 | | | Above 15 | Above 500 | +/- 4 | +/- 5 | |
| 10/11 R7 | This form wa | as developed by th | e Compressed A | Air and Gas Institute for the use of its m | embers. CAGI has not indepen | dently verified the reported data. | |