

## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Fixed Speed** 

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Atlas	Сорсо				
	Model Number: G11-1	25TM Date:	6/29/2020			
2	X Air-cooled W	/ater-cooled Type	Screw			
		# of Stages	1			
3*	Rated Capacity at Full Load Operation	ing Pressure <sup>a, e</sup> 54	acfm <sup>a,e</sup>			
4	Full Load Operating Pressure <sup>b</sup>	125	psig <sup>b</sup>			
5	Maximum Full Flow Operating Pres	ssure <sup>c</sup> 132	psig <sup>c</sup>			
6	Drive Motor Nominal Rating	15	hp			
7	Drive Motor Nominal Efficiency	91.0	percent			
8	Fan Motor Nominal Rating (if appli	cable) 0.4	hp			
9	Fan Motor Nominal Efficiency	N/A	percent			
10*	Total Package Input Power at Zero	Flow <sup>e</sup> 5.5	kW <sup>e</sup>			
11	Total Package Input Power at Rated Load Operating Pressure <sup>d</sup>	Capacity and Full 13.4	kW <sup>d</sup>			
12*	Specific Package Input Power at Ra Full Load Operating Pressure <sup>e</sup>	ted Capacity and 24.8	kW/100 cfm <sup>e</sup>			
13	Isentropic Efficiency	60.53	Percent			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.





for this data sheet. c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the

b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured

- maximum pressure attainable before capacity control begins. May require additional power. d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:
  - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	1
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
ROT 030.1	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
	Above 15	Above 529.7	+/- 4	+/- 5	