	COMPRESSOR DA Federal Uniform Test Method for Certain Rotary Compressor: Varial	Air Compressors Not A De Frequency Drive	pplicable
	MODEL DATA - FOR CO	MPRESSED AIR	
1	Manufacturer: Atlas Copco		
2	Model Number: G 200 VSD Pro-10	Date:	02-20-2024
	Air-cooled Water-cooled	Type:	Screw
	✓ Lubricated Oil-free	# of Stages:	1
3	Full Load Operating Pressure*(b)	102.0	psig*(b)
4	Drive Motor Nominal Rating	268.2	hp
5	Drive Motor Nominal Efficiency	96.5	percent
6	Fan Motor Nominal Rating (if applicable)	22.8	hp
7	Fan Motor Nominal Efficiency	89.5	percent
8*	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	263.9 Max	1,494.7	17.7
	209.7	1,226.1	17.1
	160.0	957.6	16.7
	114.7	689.1	16.6
	73.5 Min Total Package Input Power at Zero Flow*(c,d)	420.6 66.7	17.5 kW
10	Since the second		
*For mo	dels that are tested in the CAGI Performance Verification P	rogram, these items are verified	by program administrator
Notes: Member	 Consult CAGI website for a list of participants in the third p a. Measured at the discharge terminal point of the compressor pack ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet b. The operating pressure at which the Capacity and Electrical Con c. No Load Power. In accordance with ISO 1217, Annex E, if mea manufacturer may state "not significant" or "0" on the test report d. Tolerance is specified in ISO 1217, Annex E, as shown in table 	age in accordance with conditions. sumption were measured for this data sheet surement of no load power equals less than elow:	
	at specified conditions Volu <u>m3/min</u> <u>ft3/min</u>	me Flow Rate Consumption	Flow Power
	Below 0.5 Below 15	+/- 7 +/- 8	
	0.5 to 1.5 15 to 50	+/- 6 +/- 7	+/- 10
OT 021 2	1.5 to 15 50 to 500	+/- 5 +/- 6	
OT 031.2 /19 R3	Above 15 Above 500 This form was developed by the Compressed Air and Gas Institute for	-	pendently verified the reported data.