COMPRESSOR DATA SHEET Federal Uniform Test Method for Certain Air Compressors Not Applicable Rotary Compressor: Variable Frequency Drive MODEL DATA - FOR COMPRESSED AIR			
1	Model DATA - FOR CO Manufacturer: Atlas Copco	WII KESSED AIK	
1	Model Number: G 200 VSD Pro W-10	Date:	02-20-2024
2	Air-cooled Water-cooled		Screw
		Туре:	
2		# of Stages:	1
3	Full Load Operating Pressure*(b)	102.0	psig*(b)
4	Drive Motor Nominal Rating	268.2	hp
5	Drive Motor Nominal Efficiency	96.5	percent
6	Fan Motor Nominal Rating (if applicable)	0.9	hp
7	Fan Motor Nominal Efficiency	40.6	percent
8*	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	260.1 Max	1,494.7	17.4
	205.0	1,226.1	16.7
	154.6	957.6	16.1
	108.5	689.1	15.7
	66.7 Min	420.6	15.9
9*	Total Package Input Power at Zero Flow*(c,d)	58.9	kW
10	10 10 10 10 10 10 10 10 10 10		
		pacity (ACFM)	1000
 *For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org Notes: Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report. Tolerance is specified in ISO 1217, Annex E, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document. Volume Flow Rate <u>Volume Flow Rate Consumption Flow Power</u> <u>Mo Load / Zero Flow Power</u> <u>M3/min ft3/min % %</u> 			
	Below 0.5 Below 15	+/- 7 +/- 8	
	0.5 to 1.5 15 to 50 1.5 to 15 50 to 500	+/- 6 +/- 7 +/- 5 +/- 6	+/- 10
OT 031.2	1.5 to 15 50 to 500 Above 15 Above 500	+/- 5 +/- 6 +/- 5	
2/19 R3	This form was developed by the Compressed Air and Gas Institute for	he use of its members. CAGI has not inde	pendently verified the reported data.