COMPRESSOR DATA SHEET Federal Uniform Test Method for Certain Air Compressors Not Applicable Rotary Compressor: Variable Frequency Drive MODEL DATA - FOR COMPRESSED AIR			
1	Manufacturer: Atlas Copco		
	Model Number: G 200 VSD Pro W-10	Date:	02-20-2024
2	Air-cooled Water-cooled	Type:	Screw
	✓ Lubricated Oil-free	# of Stages:	1
3	Full Load Operating Pressure*(b)	138.0	psig*(b)
4	Drive Motor Nominal Rating	268.2	hp
5	Drive Motor Nominal Efficiency	96.5	percent
6	Fan Motor Nominal Rating (if applicable)	0.9	hp
7	Fan Motor Nominal Efficiency	40.6	percent
8*	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	250.2 Max	1,285.5	19.5
	202.3	1,070.0	18.9
	157.7	854.4	18.5
	116.5	638.8	18.2
	78.1 Min	423.2	18.5
9*	Total Package Input Power at Zero Flow*(c,d)	58.9	kW
10	30 25 20 15 10 200 400 600 800 1000 1200 1400 1600 Capacity (ACFM)		
	Cu	Jucity (Activity	
<ul> <li>*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator         Consult CAGI website for a list of participants in the third party verification program: www.cagi.org         Notes:         <ul> <li>Measured at the discharge terminal point of the compressor package in accordance with                  ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.</li> <li>The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.</li> <li>No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,                  manufacturer may state "not significant" or "0" on the test report.</li> <li>Tolerance is specified in ISO 1217, Annex E, as shown in table below:                  NOTE: The terms "power" and "energy" are synonymous for purposes of this document.</li> </ul> </li> </ul>			
Compressed Air & Gas Institute	Volume Flow Rate at specified conditions Volum	he Flow Rate Specific Energy Consumption	V No Load / Zero Flow Power
	<u>m3 / min</u> <u>ft3 / min</u>	% %	
	Below 0.5 Below 15	+/- 7 +/- 8	
	0.5 to 1.5 15 to 50	+/- 6 +/- 7	+/- 10
ROT 031.2	1.5 to 15         50 to 500           Above 15         Above 500	+/- 5 +/- 6 +/- 4 +/- 5	
12/19 R3	This form was developed by the Compressed Air and Gas Institute for the	he use of its members. CAGI has not inde	pendently verified the reported data.