	Ro	COMPRESSOR DA Test Method for Certain tary Compressor: Variab ODEL DATA - FOR CO	Air Compressors Not A le Frequency Drive	pplicable	
1	Manufacturer:	Atlas Copco			
	Model Number:	G 250 VSD Pro W-10	Date:	02-20-2024	
2	Air-cooled Water-cooled		Туре:	Screw	
	✓ Lubricated Oil-free		# of Stages:	1	
3			# 01 Stages. 116.0		
4	Full Load Operating Pressure*(b) Drive Motor Nominal Rating		335.3	psig*(b)	
5	Drive Motor Nominal Efficiency		96.5	hp	
6	Fan Motor Nominal Rating (if applicable)		0.9	hp	
7	Fan Motor Nominal Efficiency		40.6	percent	
8*	Input Power (kW)		Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)	
	294	9 Max	1,589.9	18.5	
	230.3		1,297.7	17.7	
	171.7		1,005.5	17.1	
	118.6		713.4	16.6	
	70.6 Min		421.2	16.8	
9*	Total Package Input	Power at Zero Flow*(c,d)	68.0	kW	
10	Specific Power				
	15 - 10 - 0	300 600 Cap	900 1200 15 Dacity (ACFM)	00 1800	
*For mo Notes: Member	Consult CAGI website for a a. Measured at the disch ISO 1217, Annex E; a b. The operating pressur c. No Load Power. In a manufacturer may stat d. Tolerance is specified NOTE: The terms "po	AGI Performance Verification Pro- list of participants in the third pa- rege terminal point of the compressor packa; cfm is actual cubic feet per minute at inlet or a twhich the Capacity and Electrical Const cordance with ISO 1217, Annex E, if meass e "not significant" or "0" on the test report. in ISO 1217, Annex E, as shown in table be were" and "energy" are synonymous for purp	erry verification program: ge in accordance with onditions. mption were measured for this data sheet rrement of no load power equals less than low: poses of this document.	www.cagi.org	
Compressed Air & Gas Institut	Volume Flow Rate at specified conditions Volum		e Flow Rate Consumption	V No Load / Zero Flow Power	
	<u>m3 / min</u>	<u>ft3 / min</u>	%		
	Below 0.5	Below 15 15 to 50	+/- 7 +/- 8 +/- 6 +/- 7	+/- 10	
	1.5 to 15	50 to 500	+/- 5 +/- 6		