Atlas Copco

Member

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: Atlas Copco							
	Model Number: G132VSD-145-116	Date:	7/22/2020					
2	X Air-cooled Water-cooled	Type:	Screw					
		# of Stages:	1					
3	Full Load Operating Pressure ^b	116	psig ^b					
4	Drive Motor Nominal Rating	177	hp					
5	Drive Motor Nominal Efficiency	95	percent					
6	Fan Motor Nominal Rating (if applicable)	4.0	hp					
7	Fan Motor Nominal Efficiency	89.5	percent					
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	154.4 Max	800.0	19.3					
	137.2	719.0	19.1					
	113.3	599.0	18.9					
	89.5	477.0	18.8					
	67.1	354.0	19.0					
	44.7 Min	229.0	19.5					
<u>9*</u>	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW					
10	Isentropic Efficiency	75.93	%					
11		300.0 400.0 500.0 Capacity (ACFM) raph is only a visual representation of Scale, 10 to 35, + 5kW/100acfm increment	the data in Section 8					

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; NOTES: ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	%				
	Below 0.5	Below 17.6	+/- 7	+/- 8				
ROT 030.1	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
	1.5 to 15	53 to 529.7	+/- 5	+/- 6				
	Above 15	Above 529.7	+/- 4	+/- 5				
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.								