Atlas Copco

Member

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MODEL DATA	- FOR COMPRESSED) AIR	
1	Manufacturer:	Atlas Copco			
	Model Number:	G132VSD-145-145	Date:	7/22/2020	
2	X Air-cooled Water-cooled		Type:	Screw	
			# of Stages:	1	
3	Full Load Operating I	Pressure ^b	145	$psig^b$	
4	Drive Motor Nominal	Rating	177	hp	
5	Drive Motor Nominal	Efficiency	95	percent	
6	Fan Motor Nominal F	ating (if applicable)	4.0	hp	
7	Fan Motor Nominal E	fficiency	89.5	percent	
8*	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	155.9 Max		723.0	21.6	
	124.5		603.0	20.7	
	101.4		478.0	21.2	
	76.1		354.0	21.5	
	51.5		229.0	22.5	
	51.5 Min		229.0	22.5	
9*	Total Package Input H	Power at Zero Flow ^{c, d}	0.0	kW	
10	Isentropic Efficiency		76.10	%	
11	35.0 30.0 30.0 30.0 (KM)100 VCEM) 15.0 10.0	0.0 100.0 200.0 Note: Gra	300.0 400.0 50 Capacity (ACFM) aph is only a visual representation of the orbits and the orbits of the orbits		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; NOTES: ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	%				
	Below 0.5	Below 17.6	+/- 7	+/- 8				
ROT 030.1	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
	1.5 to 15	53 to 529.7	+/- 5	+/- 6				
	Above 15	Above 529.7	+/- 4	+/- 5				
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.								