

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

Date: 7/22/2020 Type: Screw # of Stages: 1 102 psig ^b 214 hp 95 percent
Type: Screw # of Stages: 1 102 psig ^b 214 hp
of Stages: 1 102 psig ^b 214 hp
102 psig ^b 214 hp
214 hp
95 percent
1.0 hp
40.6 percent
city (acfm) ^{a,d} Specific Power (kW/100 acfm) ^d
1062.0 16.8
997.0 16.7
797.0 16.3
594.0 16.1
388.0 16.1
284.0 16.5
0.0 kW
82.33 %

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI websitefor a list of participants in the third party verification program:

www.cagi.org

200.0

0.0

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

400.0

- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

NOTE: The terms power and energy are synonymous for purposes of this document.						
	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy	No Load / Zero Flow Power	
			Volume Flow Rate	Consumption	No Load / Zelo Flow Fower	
	$\underline{m}^3 / \underline{\min}$	ft3 / min	%	%		
	Below 0.5	Below 17.6	+/- 7	+/- 8		
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
	1.5 to 15	53 to 529.7	+/- 5	+/- 6		
	Above 15	Above 529.7	+/- 4	+/- 5		

600.0

Capacity (ACFM)

Note: Graph is only a visual representation of the data in Section 8

Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35...

800.0

1000.0

1200.0



Member

ROT 030.1

ev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.