

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MODEL DATA	- FOR COMPRESSED	AIR			
1	Manufacturer:	Atlas Copco					
Model Number: G160VSD-		G160VSD-145-138	Date:	7/22/2020			
2	2		Type:	Screw 1			
			# of Stages:				
3	Full Load Operating Pressure ^b		138	psig ^b			
4	Drive Motor Nominal Rating		214	hp			
5	Drive Motor Nominal Efficiency		95	percent			
6	Fan Motor Nominal Rating (if applicable)		1.0	hp			
7	Fan Motor Nominal Efficiency		40.6	percent			
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d			
	179.7 Max		936.0	19.2			
Out	150.6		792.0	19.0			
8*	111.1		589.0	18.9			
	73.8		383.0	19.3			
	55.9		279.0	20.0			
	55.9 Min		279.0	20.0			
9*		Total Package Input Power at Zero Flow ^{c, d}		kW			
10	Isentropic Efficiency		83.04	%			
11	35.0 30.0 25.0 20.0 15.0 10.0 0.0 100.0 200.0 300.0 400.0 500.0 600.0 700.0 800.0 900.0 1000.0 Capacity (ACFM)						

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program:

NOTES:

Member

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.									
	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy	No. 1 and / Zone Floor Decree				
				Consumption	No Load / Zero Flow Power				
	$\underline{m}^3 / \underline{\min}$	ft3 / min	%	%					
	Below 0.5	Below 17.6	+/- 7	+/- 8					
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%				
	1.5 to 15	53 to 529.7	+/- 5	+/- 6					
	Above 15	Above 529.7	+/- 4	+/- 5					

Note: Graph is only a visual representation of the data in Section $\bf 8$ Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35...

ROT 030.1

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.