Atlas Copco

Member

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

		MODEL DATA	- FOR COMPRESSEI) AIR	
1	Manufacturer:	Atlas Copco			
	Model Number:	G250VSD-145-102	Date:	7/22/2020	
2	X Air-cooled Water-cooled		Type:	Screw	
			# of Stages:	1	
3	Full Load Operating F	Pressure ^b	102	psig ^b	
4	Drive Motor Nominal	Rating	268	hp	
5	Drive Motor Nominal	Efficiency	95	percent	
6	Fan Motor Nominal R	ating (if applicable)	10.7	hp	
7	Fan Motor Nominal E	fficiency	89.9	percent	
	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	266.2 Max		1477.0	18.0	
	228.2		1294.0	17.6	
8*	195.4		1124.0	17.4	
	153.6		900.0	17.1	
	114.8		672.0	17.1	
	68.6 Min		386.0	17.8	
9*	Total Package Input P	ower at Zero Flow ^{c, d}	0.0	kW	
10	Isentropic Efficiency		77.22	%	
11	35.0 30.0 30.0 30.0 30.0 30.0 25.0 20.0 20.0 30.0 20.0 30.0 20.0 20.0 20	0.0 200.0 400.0 Note: Gra	600.0 800.0 10 Capacity (ACFM) ph is only a visual representation of the rale, 10 to 35, + 5kW/100acfm increments i		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; NOTES: ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power				
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	%					
	Below 0.5	Below 17.6	+/- 7	+/- 8					
ROT 030.1	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%				
	1.5 to 15	53 to 529.7	+/- 5	+/- 6					
	Above 15	Above 529.7	+/- 4	+/- 5					
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.									