Atlas Copco

Member

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA	- FOR COMPRESSE	D AIR	
1	Manufacturer: Atlas Copco			
	Model Number: G250VSD-145-116	Date:	7/22/2020	
2	X Air-cooled Water-cooled	Type:	Screw	
		# of Stages:	1	
3	Full Load Operating Pressure ^b	116	psig ^b	
4	Drive Motor Nominal Rating	268	hp	
5	Drive Motor Nominal Efficiency	95	percent	
6	Fan Motor Nominal Rating (if applicable)	10.7	hp	
7	Fan Motor Nominal Efficiency	89.9	percent	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	267.0 Max	1412.0	18.9	
	228.9	1234.0	18.6	
8*	206.6	1122.0	18.4	
	162.6	898.0	18.1	
	121.5	670.0	18.1	
	73.1 Min	385.0	19.0	
9*	Total Package Input Power at Zero Flow ^{c, d}	0.0	kW	
10	Isentropic Efficiency	78.42	%	
11		600.0 800.0 Capacity (ACFM) raph is only a visual representation of the Scale, 10 to 35, + 5kW/100acfm increments		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; NOTES: ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power			
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	%				
	Below 0.5	Below 17.6	+/- 7	+/- 8				
ROT 030.1	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
	1.5 to 15	53 to 529.7	+/- 5	+/- 6				
	Above 15	Above 529.7	+/- 4	+/- 5				
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.								