

## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

## **Rotary Compressor: Variable Frequency Drive**

	MODEL DA	ATA - FOR CO	OMPRESSED AIR (I	Preliminary Data)	
1	Manufacturer: Atlas	Сорсо			
2	Model Number: GA18	VSDS	Date:	2/21/2024	
	X Air-cooled V	Vater-cooled	Type:	Screw	
			# of Stages:	1	
3	Full Load Operating Pressure <sup>b</sup>		102	psig <sup>b</sup>	
4	Drive Motor Nominal Rating		25	hp	
5	Drive Motor Nominal Efficiency		94.1	percent	
6	Fan Motor Nominal Rating (if applicable)		0.8	hp	
7	Fan Motor Nominal Efficiency		80	percent	
8*	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm)	l
	<b>24.6</b> Max		138.1	17.8	
	21.2		120.0	17.7	
	16.9		98.0	17.2	
	12.7		75.1	16.9	
	8.7		50.3	17.3	
	3.0 Min		12.2	25.0	
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>		0.0	kW	
10	Isentropic Effeciency		77.53	%	٦
11	35.0 30.0 30.0 25.0 20.0 15.0 10.0	te: Y-Axis Scale, 10 to 35	50.0 75.0  Capacity (ACFM)  visual representation of the data in Sc 5, + 5kW/100acfm increments if necesse e, 0 to 25% over maximum capacity		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program:


NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.





ROT 030.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data