

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

1	Manufacturer: Atlas Copco				
2	Model Number: GA7VSDS-175	Date:	2/21/2024	2/21/2024	
	X Air-cooled Water-cool	ed Type:	Screw	Screw	
		# of Stages:	1		
3	Full Load Operating Pressure ^b	102	psig ^b		
4	Drive Motor Nominal Rating	10	hp		
5	Drive Motor Nominal Efficiency	93.2	percent		
6	Fan Motor Nominal Rating (if applicab	le) 0.6	hp	hp	
7	Fan Motor Nominal Efficiency	80	percent		
8*	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d		
	9.0	Max 47.8	18.7		
	8.2	44.2	18.6		
	7.5	40.5	18.5		
	6.1	32.9	18.6		
	4.5	22.9	19.8		
	3.3	Min 13.5	24.1		
)*	Total Package Input Power at Zero Flo		kW		
0	Isentropic Effeciency	70.42	%		
11	35.0 30.0	25.0 Capacity (ACFM)			
	Note: Y-Axis Sca	a is only a visual representation of the data in Sec le, 10 to 35, + 5kW/100acfm increments if necessar Axis Scale, 0 to 25% over maximum capacity			

Rotary Compressor: Variable Frequency Drive

Member

ROT 030.1

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
 - b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
 - c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,



NOTES:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

ias Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power				
	m ³ / min	<u>ft3 / min</u>	%	%					
	Below 0.5	Below 17.6	+/- 7	+/- 8					
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%				
	1.5 to 15	53 to 529.7	+/- 5	+/- 6					
	Above 15	Above 529.7	+/- 4	+/- 5					
form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.									

12/19 Rev 3 This fo