

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR				
1	Manufacturer:	Atlas Copco		
	Model Number:	G132-145	Date:	7/22/2020
2	Air-cooled	X Water-cooled	Type:	Screw
			# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure a, e		731	acfm ^{a,e}
4	Full Load Operating Pressure b		145	psig ^b
5	Maximum Full Flow Operating Pressure ^c		145	psig ^c
6	Drive Motor Nominal Rating		177	hp
7	Drive Motor Nominal Efficiency		95.0	percent
8	Fan Motor Nominal Rating (if applicable)		1.0	hp
9	Fan Motor Nominal Efficiency		40.6	percent
10*	Total Package Input Power at Zero Flow ^e		31.3	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d		151	kW^d
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure		20.7	kW/100 cfm ^e
13	Isentropic Efficiency		78.67	Percent

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI websitefor a list of participants in the third party verification program:

www.cagi.org


NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ROT 030.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.