

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Fixed Speed

| MODEL DATA - FOR COMPRESSED AIR | | | | |
|---------------------------------|-------------------------------------------------------------------------------------------|----------------|--------------|-------------------------|
| 1 | Manufacturer: | Atlas Copco | | |
| | Model Number: | G250-145 | Date: | 7/22/2020 |
| 2 | Air-cooled | X Water-cooled | Type: | Screw |
| | | | # of Stages: | 1 |
| 3* | Rated Capacity at Full Load Operating Pressure a, e | | 1307 | acfm ^{a,e} |
| 4 | Full Load Operating Pressure b | | 145 | psig ^b |
| 5 | Maximum Full Flow Operating Pressure ^c | | 145 | psig ^c |
| 6 | Drive Motor Nominal Rating | | 335 | hp |
| 7 | Drive Motor Nominal Efficiency | | 95.0 | percent |
| 8 | Fan Motor Nominal Rating (if applicable) | | 1.0 | hp |
| 9 | Fan Motor Nominal Efficiency | | 40.6 | percent |
| 10* | Total Package Input Power at Zero Flow ^e | | 64.1 | kW ^e |
| 11 | Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d | | 255 | kW^d |
| 12* | Specific Package Input Power at Rated Capacity and Full Load Operating Pressure | | 19.5 | kW/100 cfm ^e |
| 13 | Isentropic Efficiency | | 83.29 | Percent |

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI websitefor a list of participants in the third party verification program:


www.cagi.org

NOTES:

Member

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ROT 030.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.