COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

	DEL DATA - FOR CO	1 1	
Ianufacturer:	Atlas Copco		
odel Number:	GA 110 VSD-8.6	Date:	06-29-2020
ir-cooled	Water-cooled	Type:	Screw
		# of Stages:	1
oad Operating Pre	essure*(b)	125.0	psig*(b)
Drive Motor Nominal Rating		147.5	hp
Drive Motor Nomnial Efficiency		96.0	percent
otor Nominal Rat	ing (if applicable)	5.9	hp
Fan Motor Nominal Efficiency		80.0	percent
Input Po	wer (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
129.9	Max	736.0	17.6
105.5		603.1	17.5
82.2		470.2	17.5
59.9		337.3	17.8
38.3	Min	204.4	18.7
Total Package Input Power at Zero Flow*(c,d)		0.0	kW
Isentropic Efficiency		85.1	%
Specific Power (kW/100ACFM) 10 10 0	200	400 600	800
	0		0 200 400 600 Capacity (ACFM)

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

Notes:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
<u>m3 / min</u>	ft3 / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3