## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

	Rotary Compressor: Variable MODEL DATA - FOR COM		
1	Manufacturer: Atlas Copco		
2	Model Number: GA 132 VSD-8.6	Date:	06-29-2020
	✓ Air-cooled	Type:	Screw
		# of Stages:	1
3*	Full Load Operating Pressure*(b)	125.0	psig*(b)
4	Drive Motor Nominal Rating	177.0	hp
5	Drive Motor Nomnial Efficiency	96.2	percent
6	Fan Motor Nominal Rating (if applicable)	5.9	hp
7	Fan Motor Nominal Efficiency	80.0	percent
8*	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	155.3 Max	883.3	17.6
	124.0	713.6	17.4
	93.8	543.9	17.2
	65.3	374.2	17.4
	38.1 Min	204.5	18.6
9*	Total Package Input Power at Zero Flow*(c,d)	0.0	kW
10	Isentropic Efficiency	86.2	%
11	Specific Power (kW/100ACFM)  10  0  200  400  Car	600 800 Dacity (ACFM)	1000

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

Notes:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

  NOTE: The terms "power" and "energy" are synonymous for purposes of this do

Member

Volume Flow Rate			Specific Energy	No Load / Zero
at specified conditions		Volume Flow Rate	Consumption	Flow Power
<u>m3 / min</u>	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	1

ROT 031.1

12/19 Rev 3