COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Atlas Copco					
	Model Number: GA 315-8.6	Date:	03-08-2022			
2	✓ Air-cooled	Type:	Screw			
	✓ Oil-injected ☐ Oil-free	# of Stages:	1			
3*	Rated Capacity at Full Load Operating Pressure*(a,e)	2,010.7	(acfm) *(a,e)			
4	Full Load Operating Pressure*(b)	125.0	psig*(b)			
5	Maximum Full Flow Operating Pressure*(c)	132.0	psig*(c)			
6	Drive Motor Nominal Rating	214.6 & 214.6	hp			
7	Drive Motor Nominal Efficiency	96.2 & 96.2	percent			
8	Fan Motor Nominal Rating (if applicable)	4.0 & 4.0 & 4.0	hp			
9	Fan Motor Nominal Efficiency	79.9 & 79.9 & 79.9	percent			
10*	Total Package Input Power at Zero Flow*(e)	79.9	kW*(e)			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)	359.5	kW*(d)			
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e) *For models that are tested in the CAGI Performance Verification Programmer Programmer Verification Programmer Ver	17.9	kW/100 cfm*(e)			

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Notes:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured

Member

- for this data sheet. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. Total package input power at other than reported operating points will vary with control strategy.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate			Specific Energy	No Load / Zero
at specified conditions		Volume Flow Rate	Consumption	Flow Power
<u>m3 / min</u>	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 030.2

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.

12/19 Rev 3