

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR

1	Manufacturer: Atlas Copco														
2	Model Number: GA 200 VSD+-10.4	Date:	03-10-2022												
	<input checked="" type="checkbox"/> Air-cooled <input type="checkbox"/> Water-cooled	Type:	Screw												
	<input checked="" type="checkbox"/> Lubricated <input type="checkbox"/> Oil-free	# of Stages:	1												
3	Full Load Operating Pressure*(b)	150.0	psig*(b)												
4	Drive Motor Nominal Rating	147.5 & 147.5	hp												
5	Drive Motor Nominal Efficiency	96.3 & 96.3	percent												
6	Fan Motor Nominal Rating (if applicable)	4.0 & 4.0 & 4.0	hp												
7	Fan Motor Nominal Efficiency	83.0 & 83.0 & 83.0	percent												
8*	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)												
	263.0 Max	1,323.2	19.9												
	219.2	1,090.4	20.1												
	176.7	857.5	20.6												
	135.1	624.6	21.6												
9*	94.0 Min	391.8	24.0												
	Total Package Input Power at Zero Flow*(c,d)	0.1	kW												
10	<table border="1"> <caption>Graph Data Points</caption> <thead> <tr> <th>Capacity (ACFM)</th> <th>Specific Power (kW/100ACFM)</th> </tr> </thead> <tbody> <tr> <td>400</td> <td>24.0</td> </tr> <tr> <td>624.6</td> <td>21.6</td> </tr> <tr> <td>857.5</td> <td>20.6</td> </tr> <tr> <td>1090.4</td> <td>20.1</td> </tr> <tr> <td>1323.2</td> <td>19.9</td> </tr> </tbody> </table>			Capacity (ACFM)	Specific Power (kW/100ACFM)	400	24.0	624.6	21.6	857.5	20.6	1090.4	20.1	1323.2	19.9
Capacity (ACFM)	Specific Power (kW/100ACFM)														
400	24.0														
624.6	21.6														
857.5	20.6														
1090.4	20.1														
1323.2	19.9														

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Notes:

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member



Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	+/- 10
0.5 to 1.5	15 to 50	+/- 6	+/- 7	
1.5 to 15	50 to 500	+/- 5	+/- 6	

ROT 031.2
12/19 R3

Above 15	Above 500	+/- 4	+/- 5	
----------	-----------	-------	-------	--

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.