	Federal Unifor	COMPRES m Test Method fo		A SHEET .ir Compressors Not A	applicable	
		Rotary Con			••	
		MODEL DATA -	FOR COM	IPRESSED AIR		
1	Manufacturer:	Atlas Copco				
	Model Number	GA 355 V	W-8.6	Date:	07-06-2020	
2	Air-cooled	✔ Water-co	oled	Type:	Screw	
	✓ Oil-injected	Oil-free		# of Stages:	1	
3*	Rated Capacity at Full Load Operating Pressure*(a,e)			1,987.6	(acfm) *(a,e)	
4	Full Load Operating Pressure*(b)			125.0	psig*(b)	
5	Maximum Full Flow Operating Pressure*(c)		re*(c)	132.0	psig*(c)	
6	Drive Motor Nominal Rating			442.5	hp	
7	Drive Motor Nominal Efficiency			96.2	percent	
8	Fan Motor Nominal Rating (if applicable)		ole)		hp	
9	Fan Motor Nominal Efficiency				percent	
10*	Total Package Input Power at Zero Flow*(e)		w*(e)	86.8	kW*(e)	
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)			348.5	kW*(d)	
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)			17.5	kW/100 cfm*(e)	
ä	For models that are tested in	the CAGI Performance Ve	erification Progra	am, these items are verified by p	l rogram administrator	
Notes:	Consult CAGI website for a list of participants in the third party verification program: www.cagi.org a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.					
Member	 b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet. 					
		accordance with ISO 1217 tate "not significant" or "0"		easurement of no load power equ	als less than 1%,	
AGI essed Air & Gas Institute	 d. Total package input e Tolerance is specifi 	power at other than report ed in ISO 1217, Annex E, a	ed operating point as shown in table	nts will vary with control strateg	у.	
Charles and Charle	NOTE: The terms "power" and "energy" are synonymous fo Volume Flow Rate			Specific Energ	y No Load / Zero	
	at specified conditions		Volume Flo			
	<u>m3 / min</u>	<u>ft3 / min</u>	%	%		
	Below 0.5	Below 15 +/-		+/- 8		
	0.5 to 1.5	15 to 50	+/- (+/- 10	
030.2	1.5 to 15 Above 15	50 to 500 +/- Above 500 +/-				
			.,		I	