	Federal Uniform	n Test Method fo		r Compressors Not A	pplicable
		Rotary Com MODEL DATA -	pressor: Fix	-	
1	Manufacturer:	Atlas Copco			
	Model Number:	GA 400-	-13.8	Date:	07-06-2020
2	✓ Air-cooled	Water-co	oled	Type:	Screw
	✓ Oil-injected	Oil-free		# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure*(a,e)			1,655.7	(acfm) *(a,e)
4	Full Load Operating Pressure*(b)			195.0	psig*(b)
5	Maximum Full Flow Operating Pressure*(c)		re*(c)	200.2	psig*(c)
6	Drive Motor Nominal Rating			496.2	hp
7	Drive Motor Nominal Efficiency			96.2	percent
8	Fan Motor Nominal Rating (if applicable)		ole)	30.0	hp
9	Fan Motor Nominal Efficiency			86.7	percent
10*	Total Package Input Power at Zero Flow*(e)		w*(e)	95.1	kW*(e)
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)			413.0	kW*(d)
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)			24.9	kW/100 cfm*(e)
	*For models that are tested in	the CAGI Performance Ve	erification Program	, these items are verified by pr	ogram administrator
Notes: Member	 Consult CAGI website for a list of participants in the third party verification program: www.cagi.org a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured 				
AGI ed Air & Gas Institute	for this data sheet. c. No Load Power. In manufacturer may st d. Total package input e Tolerance is specifie	accordance with ISO 1217 ate "not significant" or "0' power at other than report d in ISO 1217, Annex E, a	Y, Annex E, if meas " on the test report ed operating points as shown in table b	urement of no load power equa will vary with control strategy elow:	als less than 1%,
	NOTE: The terms "power" and "energy" are synonymous fo Volume Flow Rate		ynonymous for pu	Specific Energy	y No Load / Zero
	at specified conditions		Volume Flow		Flow Power
	<u>m3 / min</u> Polow 0.5	<u>ft3 / min</u> Palaw 15	%	%	
	Below 0.5 0.5 to 1.5	Below 15 15 to 50	+/- 7 +/- 6		+/- 10
	1.5 to 15 50 to 500 +/		+/- 5	+/- 6	
030.2			+/- 4	+/- 5	