

## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

<b>Rotary Compressor:</b>	Fixed Speed
---------------------------	-------------

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: A	tlas Copco				
	Model Number: G	A22-125	Date:	6/29/2020		
2	X Air-cooled	Water-cooled	Type:	Screw		
			# of Stages:	1		
3*	Rated Capacity at Full Load Operating Pressure <sup>a, e</sup>		134	acfm <sup>a,e</sup>		
4	Full Load Operating Pressure <sup>b</sup>		125	psig <sup>b</sup>		
5	Maximum Full Flow Operating Pressure <sup>c</sup>		132	psig <sup>c</sup>		
6	Drive Motor Nominal Rating		30	hp		
7	Drive Motor Nominal Efficiency		91.7	percent		
8	Fan Motor Nominal Rating (if applicable)		0.4	hp		
9	Fan Motor Nominal Efficiency77.0		77.0	percent		
10*	Total Package Input Power at 2	Zero Flow <sup>e</sup>	6.9	kW <sup>e</sup>		
11	Total Package Input Power at I Load Operating Pressure <sup>d</sup>	Rated Capacity and Full	28.2	$\mathrm{kW}^{\mathrm{d}}$		
12*	Specific Package Input Power Full Load Operating Pressure <sup>e</sup>		21.0	kW/100 cfm <sup>e</sup>		
13	Isentropic Efficiency		71.37	Percent		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI websitefor a list of participants in the third party verification program: www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.





- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
  c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:
  - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8	1
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
ROT 030.1	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
	Above 15	Above 529.7	+/- 4	+/- 5	