

## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Fixed Speed**

MODEL DATA - FOR COMPRESSED AIR (Preliminary Data)						
1	Manufacturer: Atlas	Сорсо				
	Model Number: GA5-	100	Date:	10/24/2023		
2	X Air-cooled	Water-cooled	Type:	Screw		
		#	of Stages:	1		
3*	Rated Capacity at Full Load Operating Pressure a, e		l <b>.8</b>	acfm <sup>a,e</sup>		
4	Full Load Operating Pressure <sup>b</sup>		00	psig <sup>b</sup>		
5	Maximum Full Flow Operating Pressure <sup>c</sup>		00	psig <sup>c</sup>		
6	Drive Motor Nominal Rating		6	hp		
7	Drive Motor Nominal Efficiency		0.2	percent		
8	Fan Motor Nominal Rating (if applicable)		.0	hp		
9	Fan Motor Nominal Efficiency		.0	percent		
10*	Total Package Input Power at Zero	Flow <sup>e</sup>	2	kW <sup>e</sup>		
11	Total Package Input Power at Rate Load Operating Pressure <sup>d</sup>	d Capacity and Full 7	.2	$kW^d$		
12*	Specific Package Input Power at R Full Load Operating Pressure <sup>e</sup>	ated Capacity and 22	2.6	kW/100 cfm <sup>e</sup>		
13	Isentropic Efficiency	58	.70	Percent		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

a. Measured at the discharge terminal point of the compressor package in accordance with NOTES:

- ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet. c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the

maximum pressure attainable before capacity control begins. May require additional power. d. Total package input power at other than reported operating points will vary with control strategy.



2/19

Member

e. Tolerance is specified in ISO 1217, Annex C, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy	No Load / Zero
			Volume Flow Kale	Consumption	Flow Power
	$\underline{m}^3 / \underline{min}$	<u>ft3 / min</u>	%	%	
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
ROT 030.1	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
	Above 15	Above 529.7	+/- 4	+/- 5	