## **COMPRESSOR DATA SHEET**

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR 1 Manufacturer: Atlas Copco GA 110 W-5.2 06-29-2020 Model Number: Date: Air-cooled **✓** Water-cooled 2 Screw Type: # of Stages: 1 Rated Capacity at Full Load Operating 3\* 887.2 (acfm) \*(a,e) Pressure\*(a,e) 4\* Full Load Operating Pressure\*(b) 75.0 psig\*(b) 5 Maximum Full Flow Operating Pressure\*(c) 79.8 psig\*(c) 6 147.5 **Drive Motor Nominal Rating** hp 7 Drive Motor Nominal Efficiency 95.4 percent 8 Fan Motor Nominal Rating (if applicable) 0.5 hp 9 Fan Motor Nominal Efficiency 31.0 percent 10\* Total Package Input Power at Zero Flow\*(e) 31.6 kW\*(e) Total Package Input Power at Rated Capacity 11 121.8 kW\*(d)and Full Load Operating Pressure\*(d) Specific Package Input Power at Rated Capacity 12\* 13.7 kW/100 cfm\*(e) and Full Load Operating Pressure\*(e) 13 Isentropic Efficiency 82.0 Percent

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Notes:

 Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Total package input power at other than reported operating points will vary with control strategy.
- e Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	1 87 3	11		
Volume Flow Rate			Specific Energy	No Load / Zero
at specified conditions		Volume Flow Rate	Consumption	Flow Power
<u>m3 / min</u>	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 030.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.

<sup>\*</sup>For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator