COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Atlas Copco						
	Model Number: GR 110-20	Date:	06-29-2020				
2	✓ Air-cooled Water-cooled	Type:	Screw				
		# of Stages:	2				
3*	Rated Capacity at Full Load Operating Pressure*(a,e)	476.1	(acfm) *(a,e)				
4*	Full Load Operating Pressure*(b)	200.0	psig*(b)				
5	Maximum Full Flow Operating Pressure*(c)	290.1	psig*(c)				
6	Drive Motor Nominal Rating	147.5	hp				
7	Drive Motor Nominal Efficiency	95.8	percent				
8	Fan Motor Nominal Rating (if applicable)	10.0	hp				
9	Fan Motor Nominal Efficiency	86.0	percent				
10*	Total Package Input Power at Zero Flow*(e)	25.0	kW*(e)				
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)	113.9	kW*(d)				
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)	23.9	kW/100 cfm*(e)				
13	Isentropic Efficiency	80.0	Percent				

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Notes:

 Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.

Member

- b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Total package input power at other than reported operating points will vary with control strategy.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate			Specific Energy	No Load / Zero
at specified conditions		Volume Flow Rate	Consumption	Flow Power
<u>m3 / min</u>	<u>ft3 / min</u>	%	%	
Below 0.5	Below 15	+/- 7	+/- 8	
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10
1.5 to 15	50 to 500	+/- 5	+/- 6	
Above 15	Above 500	+/- 4	+/- 5	

ROT 030.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator