

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain **Lubricated Air Compressors**

Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR				
1	Manufacturer:	Atlas Copco		
	Model Number:	G2-145TM	Date:	2/10/2023
2	X Air-cooled	Water-cooled	Type:	Screw
			# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure a, e		9.8	acfm ^{a,e}
4	Full Load Operating Pressure b		138	psig b
5	Maximum Full Flow Operating Pressure ^c		145	psig c
6	Drive Motor Nominal Rating		3	hp
7	Drive Motor Nominal Efficiency		86.5	percent
8	Fan Motor Nominal Rating (if applicable)		n/a	hp
9	Fan Motor Nominal Efficiency		n/a	percent
10*	Total Package Input Power at Zero Flow ^e		n/a	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d		3.2	kW ^d
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure ^e		32.7	kW/100 cfm ^e
13	Isentropic Efficiency		48.49	Percent

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.


Member

- for this data sheet. c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the
- maximum pressure attainable before capacity control begins. May require additional power.

b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured

- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



ROT 030.1

2/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.