COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

	• • •	FOR COMPRESSED AIR	
1	Manufacturer: Atlas Copco		
2	Model Number: ZT 30 VS	SD+-10 Date:	01-05-2024
	✓ Air-cooled Water-co	poled Type:	Tooth
	☐ Lubricated ✓ Oil-free	# of Stages:	2
3	Full Load Operating Pressure*(b)	145.0	psig*(b)
4	Drive Motor Nominal Rating	40.2	hp
5	Drive Motor Nominal Efficiency	96.3	percent
6	Fan Motor Nominal Rating (if applical	ble) 1.3	hp
7	Fan Motor Nominal Efficiency	54.0	percent
	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	33.7	Max 137.3	24.5
8*	30.0	122.5	24.5
	27.1	107.7	25.2
	24.5	92.9	26.3
	21.8	Min 78.1	27.9
9*	Total Package Input Power at Zero Fl	ut Power at Zero Flow*(c,d) 0.0	
10	Specific Power (kW/100ACFM) 10 0 20 40		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org


Notes:

Member

Compressed Air & Gas Institute

- Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document



ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.