| | Re | COMPRESSOR D n Test Method for Certa otary Compressor: Vari 10DEL DATA - FOR C | in Air Compressors Not A able Frequency Drive | pplicable | |
|--|--|--|---|---|--|
| 1 | Manufacturer: | Atlas Copco | | | |
| | Model Number: | ZT 45 VSD+-10 | Date: | 01-05-2024 | |
| 2 | ✓ Air-cooled | | Type: | Tooth | |
| | Lubricated V Oil-free | | # of Stages: | 2 | |
| 3 | Full Load Operating Pressure*(b) | | 145.0 | psig*(b) | |
| 4 | Drive Motor Nominal Rating | | 40.2 | hp | |
| 5 | Drive Motor Nominal Efficiency | | 96.3 | percent | |
| 6 | Fan Motor Nominal Rating (if applicable) | | 2.6 | hp | |
| 7 | Fan Motor Nominal Efficiency | | 59.0 | percent | |
| 8* | Input Power (kW) | | Capacity (acfm) *(a,d) | Specific Power (kW/100 acfm)*(d) | |
| | 49.5 Max | | x 205.4 | 24.1 | |
| | 40.4 | | 173.6 | 23.3 | |
| | 34.9 | | 141.7 | 24.6 | |
| | 27.4 | | 109.9 | 25.0 | |
| | 21 | | | 27.8 | |
| 9* | Total Package Input | Power at Zero Flow*(c,c | 0.0 | kW | |
| 10 | Specific Power (kW/100ACFM) 12 | | | | |
| | 10 | | | | |
| | 0 30 60 90 120 150 180 210 240 Capacity (ACFM) | | | | |
| *For mo Notes: Member CAAGI Compressed Air & Gas Institute | Consult CAGI website for a. Measured at the discl ISO 1217, Annex E; b. The operating pressu c. No Load Power. In a manufacturer may sta d. Tolerance is specified NOTE: The terms "F Volume | a list of participants in the third harge terminal point of the compressor pa acfm is actual cubic feet per minute at inl re at which the Capacity and Electrical C (ccordance with ISO 1217, Annex E, if m the "not significant" or "0" on the test rep d in ISO 1217, Annex E, as shown in tabl hower" and "energy" are synonymous for Flow Rate | ckage in accordance with et conditions. onsumption were measured for this data shee easurement of no load power equals less that ort. e below: | www.cagi.org t. 11%, zy No Load / Zero | |
| | 1 | 1 | | +/- 10 | |
| | 0.5 to 1.5 1.5 to 15 | 15 to 50 50 to 500 | +/- 6 +/- 7 +/- 5 +/- 6 | +/- 10 | |