| | Federal Unitori | | | ir Compressors Not | Applicable |
|--------------------------------|--|---|---|-----------------------------------|-----------------------|
| | | Rotary Con MODEL DATA - | - | | |
| 1 | Manufacturer: | Atlas Copco | TORCOM | | |
| 1 | Model Number: | ZR 200- | -10.4 | Date | e: 01-08-2021 |
| 2 | Air-cooled | ✓ Water-co | | Туре | |
| | Oil-injected | ✓ Oil-free | | # of Stages | |
| 3* | Rated Capacity at Full Load Operating Pressure*(a,e) | | 5 | 973.8 | (acfm) *(a,e) |
| 4 | Full Load Operating Pressure*(b) | | | 131.0 | psig*(b) |
| 5 | Maximum Full Flow Operating Pressure*(c) | | re*(c) | 150.9 | psig*(c) |
| 6 | Drive Motor Nominal Rating | | | 250.8 | hp |
| 7 | Drive Motor Nominal Efficiency | | | 94.0 | percent |
| 8 | Fan Motor Nominal Rating (if applicable) | | ble) | | hp |
| 9 | Fan Motor Nominal Efficiency | | | | percent |
| 10* | Total Package Input Power at Zero Flow*(e) | | ow*(e) | 32.2 | kW*(e) |
| 11 | Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d) | | | 185.4 | kW*(d) |
| 12* | Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e) | | | 19.0 | kW/100 cfm*(e) |
| | *For models that are tested in | the CAGI Performance V | erification Progra | m, these items are verified by | program administrator |
| Notes: | Consult CAGI website for a list of participants in the third party verification program: www.cagi.org a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. | | | | |
| Member | b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report. | | | | |
| AGI sed Air & Gas Institute | d. Total package inpute Tolerance is specifie | power at other than report d in ISO 1217, Annex E, | ted operating poin as shown in table | nts will vary with control strate | ·gy. |
| | Volume Flow Rate | | | Specific Ene | |
| | at specified m3 / min | conditions <u>ft3 / min</u> | Volume Flo | w Rate Consumptio | on Flow Power |
| | Below 0.5 | | | | |
| | 0.5 to 1.5 15 to 50 +/ 1.5 to 15 50 to 500 +/ | | +/- 7 | | +/- 10 |
| | | | +/- 5 | - 5 +/- 6 | |
| 030.2 | | | +/- 4 | +/- 5 | |