COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR C		
1	Manufacturer: Atlas Copco		
	Model Number: ZR 90 VSD-10.4	Date:	01-05-2021
2	☐ Air-cooled ✓ Water-cooled	Туре:	Screw
	☐ Lubricated ☑ Oil-free	# of Stages:	2
3	Full Load Operating Pressure*(b)	150.0	psig*(b)
4	Drive Motor Nominal Rating	120.7	hp
5	Drive Motor Nomnial Efficiency	93.5	percent
6	Fan Motor Nominal Rating (if applicable)		hp
7	Fan Motor Nominal Efficiency		percent
	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	114.1 Ma	x 470.0	24.3
8*	98.5	402.8	24.4
	83.9	335.7	25.0
	70.2	268.6	26.1
	57.3 Mi	n 201.5	28.4
9*	Total Package Input Power at Zero Flow*(c,c	12.4	kW
10	Specific Power (kW/100ACFM) 122 120 100 200	300 400 apacity (ACFM)	500

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Notes:

Measured at the discharge terminal point of the compressor package in accordance with

ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.

- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet. b.
- $No\ Load\ Power.\ In\ accordance\ with\ ISO\ 1217,\ Annex\ E,\ if\ measurement\ of\ no\ load\ power\ equals\ less\ than\ 1\%,$ manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.							
Volume Flow Rate			Specific Energy	No Load / Zero			
at specified conditions		Volume Flow Rate	Consumption	Flow Power			
<u>m3 / min</u>	<u>ft3 / min</u>	%	%				
Below 0.5	Below 15	+/- 7	+/- 8				
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10			
1.5 to 15	50 to 500	+/- 5	+/- 6				
Above 15	Above 500	+/- 4	+/- 5				
This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.							

ROT 031.2 12/19 R3