COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Fixed Speed

| MODEL DATA - FOR COMPRESSED AIR | | | | | | |
|---------------------------------|--|--------------|----------------|--|--|--|
| 1 | Manufacturer: Atlas Copco | | | | | |
| | Model Number: ZR 275-7 | Date: | 01-05-2024 | | | |
| 2 | ☐Air-cooled ✓ Water-cooled | Type: | Screw | | | |
| | ☐Oil-injected ☑Oil-free | # of Stages: | 2 | | | |
| 3* | Rated Capacity at Full Load Operating Pressure*(a,e) | 1,603.4 | (acfm) *(a,e) | | | |
| 4 | Full Load Operating Pressure*(b) | 100.0 | psig*(b) | | | |
| 5 | Maximum Full Flow Operating Pressure*(c) | 101.5 | psig*(c) | | | |
| 6 | Drive Motor Nominal Rating | 348.7 | hp | | | |
| 7 | Drive Motor Nominal Efficiency | 96.2 | percent | | | |
| 8 | Fan Motor Nominal Rating (if applicable) | | hp | | | |
| 9 | Fan Motor Nominal Efficiency | | percent | | | |
| 10* | Total Package Input Power at Zero Flow*(e) | 55.3 | kW*(e) | | | |
| 11 | Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d) | 274.5 | kW*(d) | | | |
| 12* | Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e) | 17.1 | kW/100 cfm*(e) | | | |

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Note

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- Member
- The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.



- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

| The terms power and energy are synonymous for purposes of this document. | | | | | | | |
|--|------------------|------------------|-----------------|----------------|--|--|--|
| Volume I | Flow Rate | | Specific Energy | No Load / Zero | | | |
| at specified conditions | | Volume Flow Rate | Consumption | Flow Power | | | |
| <u>m3 / min</u> | <u>ft3 / min</u> | % | % | | | | |
| Below 0.5 | Below 15 | +/- 7 | +/- 8 | | | | |
| 0.5 to 1.5 | 15 to 50 | +/- 6 | +/- 7 | +/- 10 | | | |
| 1.5 to 15 | 50 to 500 | +/- 5 | +/- 6 | | | | |
| Above 15 | Above 500 | +/- 4 | +/- 5 | | | | |

ROT 030.2

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.