COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR CO		
1	Manufacturer: Atlas Copco		
2	Model Number: ZR 132 VSD STD-10.4	Date:	01-06-2024
	☐ Air-cooled ✓ Water-cooled	Туре:	Screw
	☐ Lubricated ☑ Oil-free	# of Stages:	2
3	Full Load Operating Pressure*(b)	150.0	psig*(b)
4	Drive Motor Nominal Rating	177.0	hp
5	Drive Motor Nominal Efficiency	95.6	percent
6	Fan Motor Nominal Rating (if applicable)		hp
7	Fan Motor Nominal Efficiency		percent
8*	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	142.9 Max	671.5	21.3
	128.9	605.3	21.3
	115.5	539.1	21.4
	102.4	473.0	21.7
	89.7 Min	406.8	22.0
9*	Total Package Input Power at Zero Flow*(c,d)	13.0	kW
10	Specific Power (KW/100ACFM) Specific Power (KW/100ACFM) 10 0 100 200 300 Cap	100 200 300 400 500 600 700 800 Capacity (ACFM)	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Notes:

Member

Compressed Air & Gas Institute

- Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Volume Flow Rate Specific Energy No Load / Zero Volume Flow Rate at specified conditions Consumption Flow Power $\underline{m3\ /\ min}$ ft3 / min % % Below 0.5 Below 15 +/- 7 +/- 8 0.5 to 1.5 15 to 50 +/- 6 +/- 7 +/- 10 +/- 5 +/- 6 1.5 to 15 50 to 500 +/- 4 +/- 5 Above 15 Above 500

ROT 031.2

12/19 R3 This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.