	Ro	COMPRESSOR DA Test Method for Certain tary Compressor: Variat ODEL DATA - FOR CO	Air Compressors Not A le Frequency Drive	pplicable	
1	Manufacturer:	Atlas Copco	MI RESSED AIR		
	Model Number:	ZR 160 VSD+-10.4	Date:	01-06-2024	
2	Air-cooled Vater-cooled		Туре:	Screw	
	Lubricated V Oil-free		# of Stages:	2	
3	Full Load Operating P		125.0	 psig*(b)	
4	Drive Motor Nominal Rating		107.3 & 107.3	hp	
5	Drive Motor Nominal Efficiency		97.0 & 97.0	percent	
6	Fan Motor Nominal Rating (if applicable)			hp	
7	Fan Motor Nominal Efficiency			percent	
8*	Input Power (kW)		Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)	
	171.2 Max		902.1	19.0	
	131.9		718.1	18.4	
	97.9		534.0	18.3	
	67.2		349.9	19.2	
	37.		165.8	22.7	
9*	Total Package Input	Power at Zero Flow*(c,d)	0.0	kW	
10	Specific Power			-•	
	10				
	0 200 400 600 800 1000 Capacity (ACFM)				
*For m Notes: Member CAAG (onpressed Air & Gas Institu	Consult CAGI website for a a. Measured at the discha ISO 1217, Annex E; au b. The operating pressure c. No Load Power. In ac manufacturer may stat d. Tolerance is specified	list of participants in the third p rge terminal point of the compressor pack: fin is actual cubic feet per minute at inlet at which the Capacity and Electrical Cons cordance with ISO 1217, Annex E, if meas e "not significant" or "0" on the test report in ISO 1217, Annex E, as shown in table b wer" and "energy" are synonymous for pu- low Rate	age in accordance with conditions. umption were measured for this data sheet urement of no load power equals less than elow:	www.cagi.org 1%,	
	0.5 to 1.5	15 to 50	+/- 6 +/- 7	+/- 10	
	1.5 to 15	50 to 500	+/- 5 +/- 6		
T 031.2	Above 15	Above 500	+/- 4 +/- 5		