[	Ro	COMPRESSO n Test Method for C otary Compressor: \ 10DEL DATA - FO	ertain Variab	Air Compr le Frequenc	y Drive	pplicable
1	Manufacturer:	Atlas Copco				
	Model Number:	ZR 250 VSD-	-8.6		Date:	01-06-2024
2	Air-cooled				Type:	Screw
			# of Stages:		2	
3	Full Load Operating			124.7		psig*(b)
4	Drive Motor Nominal Rating		335.3		hp	
5	Drive Motor Nominal Efficiency		95.2		percent	
6	Fan Motor Nominal Rating (if applicable)				hp	
7	Fan Motor Nominal Efficiency					percent
8*	Input Power (kW)			Capacity (acfm) *(a,d)		Specific Power (kW/100 acfm)*(d)
	269.6 Max			1,399.1		19.3
	225.6			1,177.5		19.2
	185.4			955.9		19.4
	148.1			73	4.3	20.2
	112.8 Min			512.7		22.0
9*	Total Package Input	Power at Zero Flow	*(c,d)	2	0.8	kW
10	Specific Power (kw/100ACFM) <sup>57</sup>					
	10 0 200 400 600 800 1000 1200 1400 1600 Capacity (ACFM)					
*For mo Notes: Member CAAGI Compressed Air & Gas Institut	ISO 1217, Annex E; b. The operating pressu c. No Load Power. In a manufacturer may sta d. Tolerance is specified NOTE: The terms "p Volume		e third pa essor packag te at inlet co trical Consu E, if measu test report. a in table be ous for purp Volum	rty verificatior re in accordance wi anditions. mption were measu rement of no load p ow:	n program: th red for this data shee power equals less than	www.cagi.org t. 11%, y No Load / Zero
	1.5 to 15	50 to 500		+/- 5	+/- 6	
	Above 15	Above 500		+/- 4	+/- 5	