COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR CO		
1	Manufacturer: Atlas Copco		
2	Model Number: ZR 315 VSD-8.6	Date:	01-06-2024
	☐ Air-cooled ✓ Water-cooled	Туре:	Screw
	☐ Lubricated ☑ Oil-free	# of Stages:	2
3	Full Load Operating Pressure*(b)	124.7	psig*(b)
4	Drive Motor Nominal Rating	401.0	hp
5	Drive Motor Nominal Efficiency	94.7	percent
6	Fan Motor Nominal Rating (if applicable)		hp
7	Fan Motor Nominal Efficiency		percent
	Input Power (kW)	Capacity (acfm) *(a,d)	Specific Power (kW/100 acfm)*(d)
	324.7 Max	1,642.0	19.8
8*	261.5	1,359.6	19.2
	207.0	1,077.3	19.2
	158.0	795.0	19.9
	112.8 Min	512.7	22.0
9*	Total Package Input Power at Zero Flow*(c,d)	20.8	kW
10	Sbecitic Power (kW/100ACFM) Specific Power (kW/100ACFM) Specific Power (kW/100ACFM) Specific Power (kW/100ACFM)		0 1800

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org


Notes:

Member

Compressed Air & Gas Institute

- Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex E; acfm is actual cubic feet per minute at inlet conditions.
- The operating pressure at which the Capacity and Electrical Consumption were measured for this data sheet.
- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document



ROT 031.2 12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.