	Federal Unifor			Air Compressors N	lot Appli	icable
		MODEL DATA -	_	-		
1	Manufacturer:	Atlas Copco				
	Model Number:	ZR 75 ST	D-10.4	]	Date:	01-05-2021
2	Air-cooled	✔ Water-co	ooled	Т	ype:	Screw
	□ Oil-injected			# of Sta	ages:	2
3*	Rated Capacity at Full Load Operating Pressure*(a,e)		424.8		(acfm) *(a,e)	
4	Full Load Operating Pressure*(b)		131.0		psig*(b)	
5	Maximum Full Flow Operating Pressure*(c)		re*(c)	150.8		psig*(c)
6	Drive Motor Nominal Rating		100.6		hp	
7	Drive Motor Nominal Efficiency		96.2		percent	
8	Fan Motor Nominal Rating (if applicable)				hp	
9	Fan Motor Nominal Efficiency					percent
10*	Total Package Input Power at Zero Flow*(e)		ow*(e)	16.4		kW*(e)
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)			84.2		kW*(d)
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)			19.8		kW/100 cfm*(e)
	*For models that are tested in	the CAGI Performance V	erification Prog	ram, these items are verifie	d by progran	n administrator
Notes:	Consult CAGI website for a list of participants in the third party verification program: www.cagi.or   a. Measured at the discharge terminal point of the compressor package in accordance with   ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.					
Member	<li>b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.</li>					
AGI ied Air & Gas Institute	<ul><li>manufacturer may st</li><li>d. Total package input</li><li>e Tolerance is specifie</li></ul>	ate "not significant" or "0 power at other than report d in ISO 1217, Annex E,	" on the test rep ted operating po as shown in tab	ints will vary with control	strategy.	s than 1%,
	Volume Flow Rate			Specific Energy		No Load / Zero
	at specified		Volume F		mption	Flow Power
	<u>m3 / min</u> Below 0.5	<u>ft3 / min</u> Below 15	9/ +/-		- 8	-
	0.5 to 1.5   15 to 50   +/     1.5 to 15   50 to 500   +/		+/-		+/- 7	+/- 10
				+/- 5 +/- 6		
030.2			4 +/	- 5		