	Federal Unifor	COMPRES m Test Method fo Rotary Con	or Certain A	Air Compressor	s Not App	olicable
		MODEL DATA -	_	_	2	
1	Manufacturer:	Atlas Copco				
	Model Number	ZR 90 ST	D-10.4		Date:	08-02-2021
2	Air-cooled	✔ Water-co	ooled		Type:	Screw
	□ Oil-injected			# of Stages:		2
3*	Rated Capacity at Full Load Operating Pressure*(a,e)		510.3		(acfm) *(a,e)	
4	Full Load Operating Pressure*(b)		150.0		psig*(b)	
5	Maximum Full Flow Operating Pressure*(c)		150.8		psig*(c)	
6	Drive Motor Nominal Rating			120.7		hp
7	Drive Motor Nominal Efficiency			96.2		percent
8	Fan Motor Nominal Rating (if applicable)		ble)			hp
9	Fan Motor Nominal Efficiency					percent
10*	Total Package Input Power at Zero Flow*(e)		ow*(e)	20.3		kW*(e)
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)			106.1		kW*(d)
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)			20.8		kW/100 cfm*(e)
:	*For models that are tested in	the CAGI Performance V	erification Prog	ram, these items are ver	ified by progr	ram administrator
Notes: Member	Consult CAGI website for a list of participants in the third party verification program: www.cagi.org a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured					
AGI ed Air & Gas Institute	for this data sheet. c. No Load Power. In manufacturer may s d. Total package input e Tolerance is specific	accordance with ISO 121 rate "not significant" or "O power at other than reported in ISO 1217, Annex E,	7, Annex E, if n " on the test rep ted operating po as shown in tab	neasurement of no load port. ints will vary with contr le below:	oower equals	
	NOTE: The terms "power" and "energy" are synonymous for Volume Flow Rate			specific Energy		No Load / Zero
	at specified conditions		Volume F	-	nsumption	Flow Power
	<u>m3 / min</u>	<u>ft3 / min</u>	%		%	
	Below 0.5	Below 15	+/-		+/- 8	
	0.5 to 1.5			- 6 +/- 7		+/- 10
030.2			+/-	- 5 +/- 6 - 4 +/- 5		
	AUGVC 13	10010 300	1-/-		(I- J	