COMPRESSOR DATA SHEET Federal Uniform Test Method for Certain Air Compressors Not Applicable Rotary Compressor: Fixed Speed						
MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer:	Atlas Copco				
	Model Number	: ZT 250	-8.6	Date:	01-08-2021	
2	Air-cooled	Water-co	oled	Type:	Screw	
	Oil-injected	✓ Oil-free		# of Stages:	2	
3*	Rated Capacity at Full Load Operating Pressure*(a,e)			1,299.3	(acfm) *(a,e)	
4	Full Load Operating Pressure*(b)			102.0	psig*(b)	
5	Maximum Full Flow Operating Pressure*(c)			124.8	psig*(c)	
6	Drive Motor Nominal Rating			300.4	hp	
7	Drive Motor Nominal Efficiency			94.6	percent	
8	Fan Motor Nominal Rating (if applicable)		ole)	10.7	hp	
9	Fan Motor Nominal Efficiency			81.3	percent	
10*	Total Package Input Power at Zero Flow*(e)		w*(e)	52.2	kW*(e)	
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)			235.3	kW*(d)	
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)			18.1	kW/100 cfm*(e)	
Notes: Member	For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured					
CAGGI Compressed Air & Gas Institute	 for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report. d. Total package input power at other than reported operating points will vary with control strategy. e Tolerance is specified in ISO 1217, Annex E, as shown in table below: NOTE: The terms "power" and "energy" are synonymous for purposes of this document. 					
		Volume Flow Rate		Specific Energy		
	-	conditions	Volume Flow	w Rate Consumption %	Flow Power	
	<u>m3 / min</u> Below 0.5	<u>ft3 / min</u> Below 15	%0 +/- 7		<u> </u>	
	0.5 to 1.5	15 to 50		+/- 7	+/- 10	
	1.5 to 15	50 to 500	+/- 6 +/- 5	+/- 6		
ROT 030.2	Above 15	Above 500	+/- 4	+/- 5		
12/19 Rev 3	This form was developed	by the Compressed Air and Gas	s Institute for the use	of its members. CAGI has not indepe	ndently verified the reported data.	