	Federal Unifor	m Test Method fo	SSOR DATA S r Certain Air (1pressor: Fixed	Compressors Not A	pplicable
		MODEL DATA -			
1	Manufacturer:	Atlas Copco			
	Model Number:	ZT 200	-8.6	Date:	08-11-2021
2	Air-cooled	Water-co	ooled	Type:	Screw
	Oil-injected	✔ Oil-free		# of Stages:	2
3*	Rated Capacity at Full Load Operating Pressure*(a,e)			1,099.3	(acfm) *(a,e)
4	Full Load Operating Pressure*(b)			124.7	psig*(b)
5	Maximum Full Flow Operating Pressure*(c)		re*(c)	124.7	psig*(c)
6	Drive Motor Nominal Rating			250.8	hp
7	Drive Motor Nominal Efficiency			94.4	percent
8	Fan Motor Nominal Rating (if applicable)		ole)	10.7	hp
9	Fan Motor Nominal Efficiency			81.3	percent
10*	Total Package Input Power at Zero Flow*(e)		w*(e)	43.3	kW*(e)
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)			215.7	kW*(d)
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)			19.6	kW/100 cfm*(e)
	*For models that are tested in	the CAGI Performance V	erification Program, th	nese items are verified by pro	ogram administrator
Notes: Member	Consult CAGI website for a list of participants in the third party verification program: www.cagi.org a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. www.cagi.org b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured				
AGI	for this data sheet. c. No Load Power. In manufacturer may st	accordance with ISO 1217 ate "not significant" or "0	7, Annex E, if measure " on the test report.	ement of no load power equa	ls less than 1%,
sed Air & Gas Institute	e Tolerance is specifie	ed in ISO 1217, Annex E, a power" and "energy" are s	as shown in table belo	w:	
	Volume Flow Rate at specified conditions			Specific Energy	
	at specified <u>m3 / min</u>	<u>ft3 / min</u>	Volume Flow Ra	ate Consumption %	Flow Power
	Below 0.5	Below 15	+/- 7	+/- 8	
	0.5 to 1.5			/- 6 +/- 7	+/- 10
			+/- 5	+/- 6	
030.2			+/- 4	+/- 5	