COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Fixed Speed

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Atlas Copco						
	Model Number: ZT 275-10.4	Date:	08-11-2021				
2	✓ Air-cooled	Туре:	Screw				
	☐ Oil-injected ☑ Oil-free	# of Stages:	2				
3*	Rated Capacity at Full Load Operating Pressure*(a,e)	1,350.9	(acfm) *(a,e)				
4	Full Load Operating Pressure*(b)	150.0	psig*(b)				
5	Maximum Full Flow Operating Pressure*(c)	150.8	psig*(c)				
6	Drive Motor Nominal Rating	348.7	hp				
7	Drive Motor Nominal Efficiency	94.9	percent				
8	Fan Motor Nominal Rating (if applicable)	10.7	hp				
9	Fan Motor Nominal Efficiency	81.3	percent				
10*	Total Package Input Power at Zero Flow*(e)	54.1	kW*(e)				
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure*(d)	289.0	kW*(d)				
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure*(e)	21.4	kW/100 cfm*(e)				

*For models that are tested in the CAGI Performance Verification Program, these items are verified by program administrator

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

Note

- Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
- Member
- The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.



- No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume	Flow Rate		Specific Energy	No Load / Zero			
at specified conditions		Volume Flow Rate	Consumption	Flow Power			
<u>m3 / min</u>	<u>ft3 / min</u>	%	%				
Below 0.5	Below 15	+/- 7	+/- 8				
0.5 to 1.5	15 to 50	+/- 6	+/- 7	+/- 10			
1.5 to 15	50 to 500	+/- 5	+/- 6				
Above 15	Above 500	+/- 4	+/- 5				

ROT 030.2

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data.